



# Wall Padding Quote Request

253 Mansfield Ave  
Norton, MA 02766  
www.fullcirclepadding.com  
1-800-875-7780

Please complete form and provide images of your area(s). Then e-mail to Colin@fullcirclepadding.com or fax form to 508-285-2502

**Bill To:**  
 Company Name \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip: \_\_\_\_\_  
 Contact Name: \_\_\_\_\_  
 Phone Number (\_\_\_\_) \_\_\_\_\_  
 Fax Number: (\_\_\_\_) \_\_\_\_\_  
 Cell Number: (\_\_\_\_) \_\_\_\_\_  
 Email Address: \_\_\_\_\_

**Ship To:**  
 Company Name \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip: \_\_\_\_\_  
 Contact Name: \_\_\_\_\_  
 Phone Number (\_\_\_\_) \_\_\_\_\_  
 Fax Number: (\_\_\_\_) \_\_\_\_\_  
 Cell Number (\_\_\_\_) \_\_\_\_\_  
 Email Address: \_\_\_\_\_

Commercial / School Address  Residential Address

With some basic information we can give you an estimate for the padding including shipping. We need the following information:

1. The length of each wall to be covered:

Wall 1	_____	Wall 2	_____
Wall 3	_____	Wall 4	_____
Wall 5	_____	Wall 6	_____
Wall 7	_____	Wall 8	_____

- 2. The height of the wall pads. Standard sizes are 5, 6, and 7' high but any custom size can be made \_\_\_\_\_
- 3. How many cutouts are needed for outlets, switches vents? All cutouts are done at the factory. \_\_\_\_\_
- 4. Do you want digital graphics? If yes how many 2' wide pads would you like graphics on? \_\_\_\_\_
- 5. Do you need any round or square post pads, or I beam pads needed? Measurements are required for these, please use the appropriate how to measure page. \_\_\_\_\_
- 6. Are there any corner pads that are needed? We need the inside measurement of each side of corner \_\_\_\_\_
- 7. Our standard wall mat has FR 16oz vinyl and 2" CAL117B foam and will meet most local fire codes. \_\_\_\_\_
- 7A. Do you need ASTM E84 Class A Fire Rated wall padding? Please check with your local fire officials to see if this is required. \_\_\_\_\_
- 8. Installation is available throughout New England, New York City, Long Island and Northern New Jersey. Do you need installation? \_\_\_\_\_
- 9. Do you need Z-Channel for installation? \_\_\_\_\_
- 10. Please attach pictures of area(s) to be covered for accuracy.

-Wall padding is manufactured and shipped directly to you by truck. Allow approximately 5 - 6 weeks for delivery from the time of final approval. This may change during peak times. At time of delivery someone must be available to meet the truck, remove the mats and bring them inside. The truck driver is not obligated to help. The truck driver is only responsible for moving the pads to the end of the trailer. You will be responsible for removing the pads from the truck, checking them over for damage and bringing them inside. You must check carefully for damage and note it on the bill of lading before the driver leaves. Any damage reported after the driver leaves will not be covered.

-Pads being installed by Full Circle will be shipped to our warehouse and delivered by us at the time of installation.

-If Full Circle is installing the padding a representative will come to the facility to do the actual measurements. Measuring charges may apply. (Installation only available in New England, New York City, and northern New Jersey.)

If you have any questions please call us at 1-800-875-7780 or email Colin@fullcirclepadding.com



1084000 Series FR Wall Padding  
 ASTM E 84-05  
 CLASS "A"

**TEST RESULTS**

**ASTM E84-05**

Flamespread 25  
 Smoke Developed Index 350

**SPECIMEN DATA**

Time to Ignition (sec) 8  
 Time to Max FS (sec) 29  
 Maximum FS (feet) 5.3  
 Time to 980 F (sec) Never Reached  
 Time to End of Tunnel (sec) Never Reached  
 Max Temperature (F) 588  
 Time to Max Temperature (sec) 434  
 Total Fuel Burned (cubic feet) 49.57

FS\*Time Area (ft\*min) 52.5  
 Smoke Area (% Amin) 440.0  
 Unrounded FSI 27.0

**CALIBRATION DATA**

Time to Ignition of Last Red Oak (sec) 39.0  
 Red Oak Smoke Area (%A\*min) 121.0

Part Number	Description
1084118	2' x 4' x 2" E84 Class A
1084218	2' x 5' x 2" E84 Class A
1084318	2' x 6 x 2" E84 Class A
1084418	2' x 7 x 2" E84 Class A
1084518	2' x 8 x 2" E84 Class A

Testing Lab: Intertek ETL SEMKO  
 Testing Services NA, Inc  
 16015 Shady Falls Road  
 Elmendorf, Tx 78112

Series #1084000 FR Wall Padding Panels comply with the standards set forth by ASTM E84 (Flame spread index if 25 or less, Smoke development index of 450 or less). This Class "A" rated product meets NFPA 255, UL 723, ANSI 2.5 and UBC 8-1 (42-1).